



Parks Canada Agency Bid Receiving Unit  
 National Contracting Services  
 Bid Fax: 1-866-246-6893  
 Bid E-mail Address:  
[soumissionsouest-bidswest@canada.ca](mailto:soumissionsouest-bidswest@canada.ca)

This is the only acceptable email address for responses to the bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. The Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

## REVISION 004 TO A REQUEST FOR QUOTATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

**Issuing Office:**  
 Parks Canada Agency  
 National Contracting Services  
 Calgary, Alberta

<b>Title:</b> Alarms, Extinguishers and Sprinkler Code Inspection and Certification – Jasper National Park	
<b>Solicitation No.:</b> 5P420-22-0281/A	<b>Date:</b> December 13, 2023
<b>Amendment No.:</b> 004	
<b>Client Reference No.:</b> n/a	
<b>GETS Reference No.:</b> n/a	

<b>Solicitation Closes:</b> At: <b>14:00</b> On: <b>14 December 2023</b>	<b>Time Zone:</b> MST
--	--------------------------

<b>F.O.B.:</b> Plant: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other: <input type="checkbox"/>	
<b>Address Enquiries to:</b> Amy Barrett Lichter	
<b>Email Address:</b> <a href="mailto:amy.barrettlichter@pc.gc.ca">amy.barrettlichter@pc.gc.ca</a>	<b>Telephone No.:</b> 403-589-3402
<b>Fax No.:</b> 1-866-246-6893	
<b>Destination of Goods, Services, and Construction:</b> Jasper, Alberta	

### TO BE COMPLETED BY THE BIDDER

<b>Vendor/ Firm Name:</b>	
<b>Address:</b>	
<b>Telephone No.:</b>	<b>Email Address:</b>
<b>Name of person authorized to sign on behalf of the Vendor/ Firm (type or print):</b>	
<b>Signature:</b>	<b>Date:</b>

**Solicitation No.:**  
5P420-22-0281/A

**Amendment No.:**  
004

**Contracting Authority:**  
Amy Barrett Lichter

**Client Reference No.:**  
N/A

**Title:**  
Alarms, Extinguishers and Sprinkler Code Inspection and Certification – Jasper National Park

---

## **Amendment 004**

This amendment is raised to:

- A. Answer questions from bidders; and
- B. Amend Annex B Basis of Payment

### **A. Questions and Answers**

- Q20.** The new Basis of Payment in Amendment 003, items 1.2.10, 1.2.11, 2.2.10, 2.2.11, 3.2.10, 3.2.11, 4.2.10, 4.2.11, 5.2.10, and 5.2.11 request “Private Service Mains, Hydrants – 3 and 5 Year” please explain the intent.
- A20.** Annual flow test with yearly maintenance. 5 year is a complete service of the hydrant with a flow test. The 5 year can be done any year and may have to be done yearly.

### **B. Amend Annex B Basis of Payment**

**In Annex B Basis of Payment**

**Delete:** All reference to Private Service Mains, Hydrants - 3 Year, lines

**ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED**