



**MNE Engineering Inc.**  
22 Kevco Place - Box A  
Kitchener, Ontario N2C 2G5  
519 894 9408  
www.mneengineering.ca

**ADDENDUM 01**

<b>To:</b>	<b>Bidding Contractors</b>	<b>Date:</b>	October 24, 2023
		<b>Project:</b>	Grand Valley Institution for Women Yard Lighting
<b>cc:</b>	<b>Correctional Service Canada</b>	<b>Solicitation No:</b>	21465-24-4277707

*This addendum forms part of the contract documents and amends the drawings and specifications.*

**Electrical**

1. Reference Drawing E1.1, near Building GVA02, Area D
  - a. Revise tag from ER to DEL for the pole mounted light fixture within the courtyard.
  - b. The 'Continuity of Services' note need not apply to this one luminaire.
2. Reference Drawing E1.1 UNIT PRICE
  - a. In lieu of trenching, BFG raceway may be provided via a combination of pit launch and conventional drilling methods.
3. Reference Drawing E2.1, near Building GVA02, Area D.
  - a. Revise tag from ER to XB and apply Note 1 for the pole mounted light fixture within the courtyard.
4. Reference Section 26 05 00 Article 1.17. Add the following clause with respect to reuse of existing branch wiring.
  - a. The contractor shall be responsible to ensure that all new luminaires are functional at the time of training. At that time, if components are noted as being defective, the contractor shall correct the problems so that the system is in perfect working condition. Beyond the time of training, the Owner shall relieve the Contractor of any warranty work related to the existing branch wiring.

**End of Addendum**