



MNE Engineering Inc.
22 Kevco Place - Box A
Kitchener, Ontario N2C 2G5
519 894 9408
www.mneengineering.ca

ADDENDUM 02

To:	Bidding Contractors	Date:	November 1, 2023
		Project:	Grand Valley Institution for Women Yard Lighting
cc:	Correctional Service Canada	Solicitation No:	21465-24-4277707

This addendum forms part of the contract documents and amends the drawings and specifications. Receipt of addenda must be acknowledged on the Bid Form.

Electrical

1. Reference Drawing E1.1 and Section 26 05 00, Article 1.9 Continuity of Services
 - a. The Contractor will be responsible for ensuring that no more than two (2), non-adjacent luminaires are non-operational for a period of more than forty-eight hours. All other luminaires must be operational at the end of each working day.
 - b. The contractor shall provide temporary fencing and coverings surrounding excavations that may be left void at the end of each working day.

Questions/Responses

Q1. Can the existing bases be used?

R1. No. Delete the existing concrete bases per Drawing E1.1. Provide new bases per detail A/E3.1.

End of Addendum