



Parks Canada Agency Bid Receiving Unit  
 National Contracting Services  
 Bid Fax: 1-866-246-6893  
 Bid E-mail Address:  
[soumissionsouest-bidswest@canada.ca](mailto:soumissionsouest-bidswest@canada.ca)

This is the only acceptable email address for responses to the bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. The Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

## REVISION 004 TO A REQUEST FOR QUOTATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

**Issuing Office:**  
 Parks Canada Agency  
 National Contracting Services  
 Calgary, Alberta

<b>Title:</b> Fire & Life Safety Equipment Inspections & Maintenance – Manitoba Field Unit	
<b>Solicitation No.:</b> 5P420-23-0242/A	<b>Date:</b> March 22, 2024
<b>Amendment No.:</b> 004	
<b>Client Reference No.:</b> n/a	
<b>GETS Reference No.:</b> n/a	

<b>Solicitation Closes:</b> At: <b>14:00</b> On: <b>26 March 2024</b>	<b>Time Zone:</b> MDT
---	--------------------------

<b>F.O.B.:</b> Plant: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other: <input type="checkbox"/>	
<b>Address Enquiries to:</b> Amy Barrett Lichter	
<b>Email Address:</b> <a href="mailto:amy.barrettlichter@pc.gc.ca">amy.barrettlichter@pc.gc.ca</a>	<b>Telephone No.:</b> 403-589-3402
<b>Fax No.:</b> 1-866-246-6893	
<b>Destination of Goods, Services, and Construction:</b> Manitoba	

**TO BE COMPLETED BY THE BIDDER**

<b>Vendor/ Firm Name:</b>	
<b>Address:</b>	
<b>Telephone No.:</b>	<b>Email Address:</b>
<b>Name of person authorized to sign on behalf of the Vendor/ Firm (type or print):</b>	
<b>Signature:</b>	<b>Date:</b>

**Solicitation No.:**  
5P420-23-0242/A

**Amendment No.:**  
004

**Contracting Authority:**  
Amy Barrett Lichter

**Client Reference No.:**  
N/A

**Title:**  
Fire & Life Safety Equipment Inspections & Maintenance – Manitoba Field Unit

---

## **Amendment 004**

This amendment is raised to:

- A. Answer questions from bidders;

### **A. Questions and Answers**

- Q23. I do not see in Annex B Basis of Payment a pricing grid line for the Emergency Lighting at each location.**
- A23.** As per Amendment 003 Emergency Lighting Inspections have been removed from the Basis of Payment.
- Q24. Commercial cooking equipment for annual has “Grease build up” – would need a clarification on this as well for meaning.**
- What action do you want a contractor to take? Would this be KH cleaning, (always a separate item) as well as an inspection?**
- A24.** Parks Canada only requires an inspection and report of the condition of the grease build up – no cleaning of grease required within this contract.
- Q25. Can you confirm if parks Canada will have a man lift available if required for any testing?**
- A25.** Parks Canada will not have a man lift available for testing conducted within this contract.

**ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED**