



## Q&A # 1

**Date:** March 7, 2024

**Project:** Dust removal corrections to building 76 at AAFC Sherbrooke RDC

\*La version française se trouve à la page suivante

---

Bidders must make sure that their bids are based on the latest version of the tender documents published and take into consideration the following amendments and information, including any information provided on amendments or Q&A previously published for this project.

Bidders that do not comply with this requirement will be discarded.

---

### Question 1

Is there a dust collector planned for the project?

### Answer 1

No, an exhaust fan will allow dust caused by the preparation of cow feed to be evacuated.

### Question 2

Galvanized steel conduit on stainless steel support, is it mandatory that the supports be made of stainless steel, while the chimney support is required to be made of galvanized steel?

### Answer 2

See Addendum #3



## Q&R #1

**Date:** 7 Mars 2024

**Projet:** Corrections dé poussiérage au bâtiment 76 du CRD Sherbrooke d'AAC

\*The English version is on the previous page.

---

Les soumissionnaires doivent s'assurer que leurs propositions soient basées sur la version la plus récente des documents de soumission publiés et prennent en considération les informations ci-dessous, incluant toute information déjà publiée lors des amendements ou Q&Rs antérieurs.

Les propositions ne respectant pas cette exigence seront rejetées.

---

### Question 1

Est-ce qu'il y a un dé poussiéreur prévu sur le projet?

### Répondre 1

Non, un ventilateur d'évacuation permettra de faire l'évacuation de la poussière causée par la préparation de la nourriture des vaches.

### Question 2

Conduit en acier galvanisé sur support en acier inoxydable, est-ce obligatoire que les supports soient en inox, alors que le support de la cheminée est requis en acier galvanisé?

### Réponse 2

Voir Addendum #3