



<p>RETURN BIDS TO/RETOURNER LES SOUMISSIONS À:</p> <p>Bid Receiving - Environment Canada / Réception des soumissions – Environnement Canada</p> <p>Electronic Copy: soumissionsbids@ec.gc.ca</p> <p>BID SOLICITATION AMENDMENT MODIFICATION DE LA DEMANDE DE SOUMISSIONS</p> <p>The referenced Bid Solicitation is revised in this document; unless otherwise indicated, all other terms and conditions of the Bid Solicitation remain the same.</p> <p>La demande de soumissions citée en référence est modifiée dans ce document; sauf indication contraire, les modalités de la demande de soumissions demeurent les mêmes.</p>	<p>Title – Titre SOUTH SASKATCHEWAN RIVER AT MEDICINE HAT – 05AJ001 – ALBERTA - MONITORING STATION REBUILD</p>	
	<p>EC Bid Solicitation No. /SAP No. – N° de la demande de soumissions EC / N° SAP 5000078220</p>	<p>Amendment No. - N° de modification 001</p>
	<p>Amendment Date (YYYY-MM-DD) – Date de la modification (AAAA-MM-JJ) 2024-03-14</p>	
	<p>Bid Solicitation Closes (YEAR-MM-DD) - La demande de soumissions prend fin (AAAA-MM-JJ) at – à 3:00 P.M. /on – le 2024-03-19</p>	<p>Time Zone – Fuseau horaire Pacific Daylight Time (PDT)</p>
	<p>F.O.B – F.A.B See herein</p>	
	<p>Address Enquiries to - Adresser toutes questions à Helena.Lee@ec.gc.ca</p>	
	<p>Telephone No. – No de téléphone 1-778-617-2275</p>	<p>Fax No. – No de Fax</p>
	<p>Delivery Required (YEAR-MM-DD) – Livraison exigée (AAAA-MM-JJ) See herein</p>	
	<p>Destination of Services / Destination des services The monitoring station at 05AJ001 South Saskatchewan River at Medicine Hat, AB. Coordinates are approximately Lat : 50.04209°N Long : -110.67754°W</p>	
	<p>Security / Sécurité See herein</p>	
<p>Vendor/Firm Name and Address - Raison sociale et adresse du fournisseur/de l'entrepreneur</p>		
<p>Telephone No. – N° de téléphone</p>	<p>Fax No. – N° de télécopieur</p>	
<p>Name and title of person authorized to sign on behalf of Vendor/Firm: (type or print) / Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</p>		
<p>Signature</p>	<p>Date</p>	



AMENDMENT No. 001

Amendment 001 of Solicitation # **5000078220** is raised to answer questions from Suppliers.

1. QUESTIONS (Q) AND ANSWERS (A)

- Q1. In regards to the installation of the new conduit, can we follow the same path as the existing conduit?
- A1. As per 3.2.8. Excavation and installation of concrete foundation of 3.2 During Construction section of 3.0 Deliverables and Tasks in the Annex A – Specifications, the Contractor will install new conduit from proposed building site, following the same path as the existing conduit.
- Q2. Is there a geotech report for this project?
- A2. No, there is not a geotech report available for this project.
- Q3. What is the makeup of the material to be drilled for the conduit?
- A3. There is no geotechnical report for this project. It is expected that since the directional drilling of the conduit is underneath the road, that the material may be engineered fill. As per drawing C101, the conduit will be 3" HDPE conduit.
- Q4. Is it possible to use the existing conduit? Can the existing conduit be used as an insert?
- A4. As per the Deliverables and Tasks under 2.0 Scope and 3.2.8. Excavation and installation of concrete foundation of 3.2 During Construction section of 3.0 Deliverables and Tasks in the Annex A – Specifications, a separate, a new conduit is required to be installed and the existing conduit cannot be used and also cannot be used as an insert

All other terms and conditions of the Bid Solicitation remain the same.