



RETURN BIDS TO:
RETOURNER LES SUBMISSION À :
Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Fax: 1-855-983-1808
Bid Email: soumissionsami-bidsrpc@pc.gc.ca

This is the only acceptable email address for responses to bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address may not be accepted.

The maximum email file size is 15 megabytes. PCA is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

REVISION 001 TO A INVITATION TO TENDER

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the offer remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'offre demeurent les mêmes.

Issuing Office - Bureau de distribution :
Parks Canada Agency
National Contracting Services
Gatineau, Qc

Title - Sujet : Highway 436 Renovations, L'Anse aux Meadows National Historic Site, Newfoundland and Labrador	
Solicitation No. - N° de l'invitation : 5P468-23-0030/A	Date : April 6, 2023
Amendment No. - N° de modification : 001	
Client Reference No. - N° de référence du client : 2287	
GETS Reference No. N° de référence de SEAG : s/o	
Solicitation Closes - L'invitation prend fin : At - à : 2:00 PM On - le : April 18, 2023	Time Zone - Fuseau horaire NDT - HAT
F.O.B. - F.A.B. : Plant - Usine : <input type="checkbox"/> Destination : <input checked="" type="checkbox"/> Other - Autre : <input type="checkbox"/>	
Address Enquiries to - Adresser toutes demande de renseignements à : Christine Piché	
Telephone No. - N° de telephone : 873-355-8841	Fax No. -N° de télécopieur : 1-855-983-1808
Email Address – Courriel : Christine.piche@pc.gc.ca	
Destination of Goods, Services, and Construction - Destination des biens, services, et construction : See Herein	
TO BE COMPLETED BY THE BIDDER - À REMPLIR PAR LE SOUMISSIONNAIRE	
Vendor/ Firm Name - Nom du fournisseur/ de l'entrepreneur :	
Address - Adresse :	
Telephone No. - N° de telephone :	Fax No. - N° de télécopieur :
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Signature :	Date :

Solicitation No. - N° de l'invitation :
5P468-23-0033/A

Amd. No. - N° de la modif. :
001

Contracting Authority - Autorité contractante :
Christine Piché

Client Ref. No. - N° de réf. du client :
2287

Title – Titre :
Highway 436 Renovations, L'Anse aux Meadows National Historic Site, Newfoundland and Labrador

AMENDMENT 001

This amendment is raised to:

- A) Answer questions from bidders;
- B) Addition of Solicitation Attachment document

A. QUESTIONS AND ANSWERS

- Q1 Will Parks Canada accept Aluminized Type 2 corrugated steel pipe as an approved equivalent to the 1200mm and 1000mm SRPE culverts as identified under Section 33 42 13?
- A1 Parks Canada shall accept Poly-laminated Aluminized Type 2 Corrugated Steel Pipe as an acceptable equivalent. Bidders should refer to the specification change as per this Amendment (#2) – Section 33 42 13.

B. ADDITION OF A SOLICITATION ATTACHMENT DOCUMENT

Refer to the document below uploaded on April 6, 2023.

2023-04-06 -Revision to specs document

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED