

Annual Fire Inspection

Devices and Locations

21401-28-4415636

Correctional Service Canada
445 Union St. West
Kingston, ON
K7L 2R8

Device Legend:

Device	Description
M	Manual Pull Station
RHT	Heat Detector, Restorable
HT	Heat Detector, Non-restorable
S	Smoke Detector
RI	Remote Indicator Unit
DS	Duct Smoke Detector
OD	Other Type of Detector
SFD	Supporting Field Device (Monitor)
FS	Sprinkler Flow Switch
TS	Sprinkler Tamper Switch
PS	Sprinkler Low Pressure Switch
FM	Fault Isolation Module
B	Bell
H	Horn
V	Visual Signal Appliance
SP	Cone Type Speaker
HSP	Horn Type Speaker
AD	Ancillary Device
ET	Emergency Telephone
EOL	End of Line Device
SOL	Solenoid
REL	Relay
GA	General Alarm

Westlake Hall (NTA)

West Lake Hall 455 Union Street			
Zone	Address	Location	Device
		Boiler Room	FACP
	2021	12v12ah x 2	Batts
2	1-005	At Room 248	M
2	1-005	At Room 248	EOL
2	1-005	Room 248	RHT
2	1-005	Room 245	RHT
2	1-005	Outside Room 246	S
2	1-005	Room 246	RHT
2	1-005	Room 243	RHT
2	1-005	Room 241	RHT
2	1-005	Room 244	RHT
2	1-005	Room 242	RHT
2	1-005	Room 240	RHT
2	1-005	Room 237	RHT
2	1-005	Room 236	S
2	1-005	Room 234 Inside Room 236	S
2	1-005	Outside Room 237	S
2		Outside Room 237	H/S
2	1-005	Room 230	RHT
2	1-005	Server Room Inside Room 2	S
2	1-005	Room 235 Janitors Closet	RHT
2	1-005	Room 233	RHT
2	1-005	Outside Room 233	M
5	1-005	Outside Elevator	EOL
5	1-008	Elevator Machine Room	RHT
5	1-008	Elevator Shaft	RHT
2	1-005	Main Stairwell 1	S
2	1-005	By Room 233 (Board Room)	M
2		Outside Room 231A	H/S
2	1-004	Room 231A	RHT
2	1-004	Room 232 Photocopy/Mail Rm	RHT
2	1-004	Room 229	RHT
2	1-004	Room 226	RHT
2	1-004	Room 226	RHT
2	1-004	Outside Room 212	S

2		Outside Room 212	H/S	1	1-006	Photocopier Rm By Rm 102	RHT
2	1-004	Room 210	RHT	1	1-006	Room 105 Air Handling Rod	HT
2	1-004	Room 209	HT	1		By Water Fountain	H/S
2	1-004	Room 208	RHT	1	1-006	Outside Room 108	S
2	1-004	Room 207	RHT	1	1-006	Outside Room 110	S
2	1-004	Room 206	RHT	1	1-006	Outside Room 110	M
2	1-004	Room 205	RHT	1		Outside Room 110	B
2	1-004	Room 204	RHT	1	1-006	Room 111	RHT
2	1-004	Room 203	RHT	1	1-006	Outside Room 128	S
2	1-004	Room 202	RHT	1	1-006	Room 128	HT
2	1-004	Outside Room 202	S	1	1-006	Room 119	RHT
2	1-004	Outside Room 202	M	1	1-006	Outside Room 125	S
2	1-004	Room 201	RHT	1	1-006	In Stairwell ST003	M
2	1-004	Stairwell By Room 200	S	1	1-006	In Stairwell ST003	EOL
2	1-004	Room 200	FHT				
2	1-004	Room 212	RHT				
2	1-004	Room 211 File Storage	RHT				
2	1-004	Room 214	RHT				
2	1-004	Room 216	RHT				
2	1-004	Room 218	RHT				
2	1-004	Room 220	RHT				
2	1-004	Room 215	RHT				
2	1-004	Room 217	RHT				
2	1-004	Room 222	RHT				
2	1-004	Outside Room 222	S				
2	1-004	Room 224	RHT				
2	1-004	Outside Room 224	M				
2	1-004	Outside Room 224	EOL				
2	1-004	Room 219	RHT				
1	1-007	By Door 100	M				
1	1-007	Room 134 Cloak Room	RHT				
1	1-007	Room 142 Lunch Room	HT				
1	1-007	Server Room Inside Room	S				
1	1-007	Server Power Rm Inside Rm	S				
1	1-007	Room 143 Storage	RHT				
1	1-007	Room 136 By Showcase	EOL				
1		Room 136 By Showcase	H				
1	1-007	By Door ST005 in Rm 136	M				
1	1-006	By Elevator	M				
1	1-006	Room 102	RHT				
1	1-006	Room 130	RHT				
1	1-006	Room 103	RHT				
1	1-006	Room 129	HT				
1	1-006	Room 104	RHT				
1	1-006	Room 104A	RHT				

Elmhurst House (NTA)

ElmHurst House 453 Union Street			
Zone	Address	Location	Device
		Laundry Room	FACP
		12V7ah x 2	Batts
B	1	Laundry Room	HT
B	1	Linen Storage	S
B		Outside Linen Storage	B
B	1	At Furnace	HT
B	1	At Furnace	HT
B	1	At Furnace	HT
B	1	Bottom of Stairs	M
B	1	Bottom of Stairs	EOL
1	2	Top of BSMT Stairs	M
1	2	Top of BSMT Stairs	EOL
1	2	Room 102	S
1		1st Floor hallway	B
1	2	1st Floor hallway	HT
1	2	Front Door	M
1	2	Living Room	S
1	2	Room 103	S
1	2	Room 101	S
2	3	2nd Floor Hallway	M
2	3	2nd Floor Hallway	EOL
2		2nd Floor Hallway	B
2	3	Room 201 Kitchen	RHT
2	3	Room 201	S
2	3	Room 202	S
2	3	Room 203	S
2	3	2nd Floor Hallway	S
3	4	3rd Floor Hallway	M
3	4	3rd Floor Hallway	EOL
3		3rd Floor Hallway	B
3	SIG 1	3rd Floor Hallway	EOL
3	4	3rd Floor Hallway	S
3	4	Room 301	S
3	4	Room 302	S
3	4	Room 303	S

3	4	Room 304	S
3	4	Room 302	S
3	4	Room 303	S
3	4	Room 304	S

Harmony House (NTA)

Harmony House 449 Union Street			
Level	Address	Location	Device
		Laundry Room	FACP
		12v7ah x 2	Batts
B	1	Laundry	RHT
B	1	At Facp	RHT
B	Sig	At Facp	B
B	1	Bottom of stairs	M
B	1	Bottom of stairs	EOL
B	1	Linen storage	S
1	2	Front door	M
1	2	Bottom of stairs	S
1	2	Living Room	S
1	Sig	At basement stair	B
1	2	Outside 105	S
1	2	Kitchenette	RHT
1	2	Room 105	S
1	2	Rear exit	M
1	2	Rear exit	EOL
2	3	2nd FI Hallway	M
2	Sig	2nd FI Hallway	B
2	3	2nd FI Hallway	S
2	3	Rm 201	S
2	3	Rm 202	S
2	3	Rm 203	S
3	Sig	3rd FI hallway	B
3	4	3rd FI hallway	M
3	4	3rd FI hallway	S
3	4	3rd FI hallway	EOL
3	4	Rm 301	S
3	4	Rm 302	S
3	4	Rm 303	S
1	2	Washroom 105	RHT
2	3	Rm 201 Kitchenette	RHT

Trono House (NTA)

Trono House 461 Union Street			
Zone	Address	Location	Device
		Laundry Room	FACP
		12V7ah x 2	Batts
B	1	At FACP	RHT
B	1	Linen Storage	S
B	1	By Furnace	RHT
B	1	Bottom Of Stairs	M
B		BSMT	B
B	1	At Water Heaters	RHT
B	1	Under Stairs	EOL
1	2	Front Door	M
1	2	Kitchen Room	HT
1	2	1st Floor Hall	EOL
1	2	1st Floor Hall	S
1		1st Floor Hall	B
1	2	Room 101	S
1	2	Room 102	S
1	2	Room 103	S
2	3	2nd Floor Hallway	M
2	3	2nd Floor Hallway	EOL
2		2nd Floor Hallway	B
2	3	2nd Floor Hallway	S
2	3	203 Kitchenette	HT
2	3	Room 203	S
2	3	Room 202	S
2	3	Room 201	S
2	3	Room 201 Kitchen	RHT
3		3rd Floor Hallway	B
3	SIG1	3rd Floor Hallway	EOL
3	4	3rd Floor Hallway	M
3	4	3rd Floor Hallway	EOL
3	4	3rd Floor Hallway	S
3	4	Room 301	S
3	4	Room 302	S
3	4	Room 303	S
3	4	Room 304	S

National Training Academy (NTA)

National Training Academy 443 Union Street			
Zone	Address	Location	Device
		Main Entrance	FACP
		12v26ah	Batts
B	Sig	Outside Rm 002	B
B	1-1	Outside Room 002	M
B	1-1	Room 010 Ammo Vault	HT
B	1-1	Room 003	HT
B	1-1	Elevator Lobby	RHT
B	1-1	Room 004	HT
B	1-1	Room 008	HT
B	1-1	Crawl Space South in 008	HT
B	1-1	Crawl Space South in 008	HT
B	1-1	Crawl Space South in 008	HT
B	1-1	Room 006	HT
B	1-1	Elevator Machine Room 004	RHT
B	1-1	Room 002	HT
B	1-1	Room 005	HT
B	1-1	Room 007 West	HT
B	1-1	Room 007 Center	HT
B	1-1	Room 007 East	HT
B	1-1	Room 012 North Sim Cell	RHT
B	1-1	Room 012 South Sim Cell	RHT
B	1-1	At Boiler Room 014	M
B		At Boiler Room 014	B
B	1-1	Boiler Room 014	M
B	1-1	Boiler Room 014 West	HT
B	1-1	Boiler Room 014 East	HT
B	1-1	Room 014 Under Stairs	HT
B	1-1	Room 013	HT
B	1-1	South East Exit	M
B	1-1	Room 023	HT
B	1-1	Room 022	HT
B	1-1	Room 001	RHT
B	1-1	Room 001 Storage	HT
B	1-3	Top of Stairs east 149	S

B	1-9	At East Stairs	M
B	1-9	Weight Room East	S
B	1-9	Weight Room West	S
B	1-9	Weight Room West	M
B		Weight Room	B
B	1-3	Top of Stairs	S
B	1-9	Room 030	S
B	1-9	Room 030	M
B		Room 030	B
B	1-9	Room 031	RHT
1	1-3	Room 100A Copy Room	HT
1	1-3	Outside Room 100	RHT
1	1-3	Main Office North	RHT
1	1-3	Main Office South	HT
1	1-3	Photocopy Room	HT
1	1-3	Room 105	S
1	1-3	Room 105	M
1	1-3	Lounge Room 105	S
1	1-3	Room 127	HT
1	1-3	Room 127	HT
1		Main Lobby	B
1		At Elevator	B
1	1-3	Room 125A	HT
1	1-3	Room 126	HT
1	1-3	Room 125	HT
1	1-3	Room 124	HT
1	1-3	Room 124A	HT
1	1-3	At Room 131	M
1	1-3	Room 132	RHT
1		Outside Room 132	B
1	1-3	Room 134	HT
1	1-3	Room 136	HT
1	1-3	Room 138	RHT
1	1-3	Room 140	HT
1		Outside Room 145	B
1	1-3	Room 145	HT
1	1-3	Room 142	HT
1	1-3	Room 144	HT
1	1-3	Outside Room 144	M
1	1-3	Room 128	HT
1	1-3	Room 129	HT
1	1-3	Outside Room 130	M
1		Outside Room 130	B
1	1-3	Room 130	RHT
1	1-3	Gym South East	M

1	1-3	Gym South	M
1	1-3	Gym South West	M
1		Gym North East	B
1		Gym North West	B
1	1-3	Room 147	HT
1	1-3	Room 145	HT
1		Room 139 Locker Room	B
1	1-3	Room 139 Locker Room	RHT
1	1-3	Room 139 Washroom	HT
1	1-3	Gym North East	M
1	1-3	Gym North West	M
1	1-3	Room 149 Storage	HT
1	1-3	Room 141 Gym Storage	RHT
1	1-4	Kitchen North East Exit	M
1		Kitchen North East Exit	B
1	1-4	Kitchen North East Exit	RHT
1	1-4	Servery	HT
1	1-4	At Dishwasher	HT
1	1-4	Outside Room 114	RHT
1	1-4	Room 114 Dry Food Storage	HT
1	1-4	Room 113	HT
1	1-4	Room 112 Janitors	HT
1	1-4	Room 107	HT
1	1-4	Room 107	M
1		Room 107	B
1	1-4	Kitchen Outside Room 105	RHT
1	1-4	Room 106	HT
1	1-4	Dining Room 108	HT
1	1-4	Dining Room 108	M
1	1-4	Kitchen Room 116	RHT
1	1-4	East Exit	M
2	1-7	Room 200	HT
2	1-2	Room 200	DS
2	1-7	Outside Room 200	M
2	1-7	Outside Room 200	S
2	1-7	Room 203	S
2		Outside Room 203	B
2	1-7	Room 205	S
2	1-7	Room 204	S
2	1-7	Room 204 South	HT
2	1-7	Room 206	S
2	1-7	Room 207	RHT
2	1-7	Room 208	S
2	1-7	Room 209	S
2	1-7	Room 210	S

National Training Academy (NTA)...Cont

2		Outside Room 210	B
2	1-7	Room 211	S
2	1-7	Room 212	S
2	1-7	Room 213	S
2	1-7	Room 214	S
2	1-7	Room 215	S
2	1-7	Room 216	S
2	1-7	Room 217	RHT
2	1-7	Room 218	S
2	1-7	Room 219	HT
2	1-7	Room 220	S
2	1-7	Outside Room 220	S
2		Outside Room 220	B
2	1-7	Outside Room 220	M
2	1-7	Room 222	RHT
2	1-7	Room 227	HT
2	1-7	Room 221	RHT
2	1-7	Room 223 North	RHT
2	1-7	Room 223 South	RHT
2		Exit Room 223 North	B
2	1-7	Exit Room 223 North	M
2		Room 223 South	B
2	1-7	Room 226	HT
2	1-7	Room 230	RHT
3	1-6	Room 300	HT
3	1-6	Outside Room 300	M
3	1-6	Outside Room 300	S
3	1-6	Room 303	HT
3		Outside Room 303	B
3	1-6	Room 304 North	HT
3	1-6	Room 304 North	HT
3	1-6	Room 304 South	HT
3	1-6	Room 305 North	HT
3	1-6	Room 305 South	HT
3	1-6	Room 306 North	HT
3	1-6	Room 306 South	HT
3	1-6	Room 307 North	HT
3	1-6	Room 307 South	HT
3	1-6	Room 308 North	HT
3	1-6	Room 308 South	HT
3	1-6	Room 309 North	HT
3	1-6	Room 309 South	HT
3	1-6	Room 310 North	HT
3	1-6	Room 310 South	HT
3	1-6	Room 311 North	HT

3	1-6	Room 311 South	HT
3	1-6	Room 312 North	HT
3	1-6	Room 312 South	HT
3	1-6	Room 313 North	HT
3	1-6	Room 313 South	HT
3	1-6	Room 314 North	HT
3	1-6	Room 314 South	HT
3	1-6	Room 315 North	HT
3	1-6	Room 315 South	HT
3	1-6	Room 316 North	HT
3	1-6	Room 316 South	HT
3	1-6	Room 317 North	HT
3	1-6	Room 317 South	HT
3	1-6	Room 318 North	HT
3	1-6	Room 318 South	HT
3	1-6	Room 320 North	HT
3	1-6	Room 320 South	HT
3	1-6	Room 322	RHT
3		Outside Room 322	B
3	1-6	Outside Room 322	S
3	1-6	North Top of Stairs	S
3	1-6	South Top of Stairs	S
3	1-5	Outside Room 300	DS
2	1-11	North Wing Mech Room East	HT
2	1-11	North Wing Mech Room West	HT
2	1-11	Top of Stairs	S
2	1-11	Top of Stairs	M
2	1-11	Electrical Room	HT
2	1-11	Exit to Roof	M
2		North Wing Mech Room	B
1	1-3	Main Lobby	M
1	1-3	Main Lobby	S
1	1-3	Main Lobby	S
3	1-16	Elevator Shaft	HT
2	1-10	North BSMT	DS
2	1-14	AHU #2	DS
2	1-14	AHU #3	DS
2	1-12	2nd Floor Mech Room (Gym)	DS
2	1-12	2nd Floor Mech Room (Gym)	DS
2	1-12	2nd Floor Mech Room (Gym)	DS
1	2-1	Outside Room 124	S
1	2-2	Outside Room 124A	S
1	2-3	Outside Room 128	S
1	2-4	Outside Room 130	S
1	2-5	Outside Room 130	S

1	2-6	Outside Room 132	S
1	2-7	Outside Room 134	S
1	2-8	Outside Room 135	S
1	2-9	Outside Room 139	S
1	2-10	Outside Room 142	S
1	2-11	Outside Room 142	S
1	1-11	Room 152	HT
3	1-6	Room 321	RHTEXP

Regional Headquarters (RHQ)

Regional Headquarters 445 Union Street			
Zone	Address	Location	Device
		Main Entrance	FACP
	2017	1245ah	Batts
1	6-1	Main Lobby	M
1		Main Lobby	H/V
1	6-3	At South Stair 1	M
1		At South Stair 1	H/V
1		South Stair 1	H/V
1		South Stair 1	M
1		Outside Room 104	H/V
1		Room 104	H
1		Room 105	H
1		Room 106	H
1		Room 108	H/V
1		Room 110	H/V
1		Kitchen Area	H/V
1		East Corridor	H/V
1	6-28	North East Link Exit	M
1		North East Link Exit	H/V
1	6-29	North East Link Center	M
1		North East Link Center	H/V
1	6-30	North East Link to College	M
1		North East Link to College	H/V
1	6-27	North East Stair Exit	M
1		North East Stair Exit	H/V
1	6-31	North East Stair - North Exit	M
1		Outside Room 122	H/V
1	6-24	Electical Room 123	S
1		Electical Room 123	H
1	6-25	Comm Room 122	S
1	6-26	Mech Room 121	S
1		Mech Room 121	H
1		Room 125 South	H
1	6-32	Room 125	S
1	6-33	Room 125 NW Room 125	S
1		North Office	H/V

1		North West Office	H/V
1		South West Office	H/V
1		Outside Room 129	H/V
1		Outside Room 102	H/V
1		Outside Room 116	H/V
2	6-38	Center Storage 225	S
3		South Stairs	H/V
3	6-54	South Top of Stairs	S
3	6-53	At South Stair	M
3		At South Stair	H/V
3	6-44	At South Stair	M
3		Room 304	H
3		Outside Room 304	H/V
3		Room 305	H
3		Room 306	H
3		Outside Room 306	H/V
3		Room 310	H/V
3		Room 308	H/V
3		Kitchen Area	H/V
3		East Corridor	H/V
3	6-47	North East Stair Exit	M
3		North East Stair Exit	H/V
3		North East Stairs	H/V
3	6-46	North East Top of Stairs	S
3		Outside Room 320	H/V
3		Room 320	H/V
3		Room 321	H
3		North Office	H/V
3		North West Office	H/V
3		Room 323	H
3		Room 324	H
3		Room 316	H
3	6-48	Electical Room 315	S
3	6-49	Com Room 316	S
3	6-50	Room 332 Near Elevator	S
3		West Office	H/V
3		South West Office	H/V
3	6-51	Outside Elevator	S
3	6-57	Roof- Top Supply North	DS
3	6-58	Roof- Top Return North	DS
3	6-59	Roof- Top Supply South	DS
3	6-60	Roof- Top Return South	DS
1		Room 119	H
1	6-22	Electrical Room 115	S
1	6-21	Comm Room 116	S

1	6-19	Room 103 Praction Alarm	REL
1	6-19	Room 103 Praction Troubl	REL
1	6-8	Sprinkler Room 103	S
1	6-5	Elevator Machine Room 10	S
1		Outside Room 102	H/V
1	6-2	Elevator Lobby	S
1		First Aid Room	H
2		South Stairs 1	H/V
2	6-42	South Stairs 1	M
2	6-35	South Stairs 1	M
2		Room 205	H
2		Outside Room 206	H/V
2		Room 210	H/V
2		Room 208	H/V
2		Kitchen Area	H/V
2		Outside Room 219	H/V
2		Room 219	H
2		North East Office	H/V
2		Outside Room 229	H/V
2		Room 229	H
2		Room 229	H/V
2	6-37	Room 229	S
2		North West Office	H/V
2		Outside Room 229	H/V
2		South West Office	H/V
2		Center Office	H/V
2		South Center Office	H/V
2	6-41	Outside Elevator	S
2		Outside Room 215	H/V
2	6-40	Comm Room 215	S
2	6-39	Electrical Room 216	S
2	6-36	North Stairs	M
1	6-9	Main Water Shut Off	TS
1	6-10	Back Flow Inlet	TS
1	6-11	Back Flow Outlet	TS
1	6-12	Window Sprinkler	TS
1	6-13	Main Sprinkler	FS
1	6-14	1st Floor SV	TS
1	6-15	1st Floor Flow	FS
1	6-16	Main Sprinkler SV	TS
1	6-17	Window Sprinkler	FS
1	6-18	Main Sprinkler Low Pressur	PS
3	6-52	Elevator	S
	6-1	Main Lobby	GA
	6-3	At Stair 11	GA

Regional Headquarters (RHQ)...cont

6-4	At Stair 1	GA	
6-28	Northeast Link Exit	GA	
6-29	Northeast Link Center	GA	
6-30	Northeast Link to College	GA	
6-27	Northeast Exit to Stairs	GA	
6-31	Northeast Stair- North Exit	GA	
6-53	At South Stairs	GA	
6-44	At South Stairs	GA	
6-47	Northeast Stair Exit	GA	
6-42	South Stair 1	GA	
6-35	South Stair 1	GA	
6-38	North Stairs	GA	

Isabel McNeil House

Isabel McNeil House 525 Union Street			
Zone	Address	Location	Device
		Main Entrance	FACP
		12v12ah x 2	Batts
3	4	West Exit	M
3	4	West Exit	EOL
3	4	Room 5	S
3	4	Room 1	S
3	4	Room 7	S
3		East Exit	B
3	4	East Exit	M
3	4	Top of Stairs	S
3	SIG1	East Exit	EOL
2	3	West Exit	M
2	3	Outside Room 2	S
2	3	Room 2	S
2	3	Room 3	S
2	3	Room 6	S
2	3	At top of North Stairs	M
2	3	At top of North Stairs	EOL
2		At top of North Stairs	B
2	3	Top of North Stair	S
2	3	Room 4	S
2	3	Under Stair Storage 479	RHT
1	2	South Exit	M
1	2	Room 470	RHT
1	2	Room 471	RHT
1	2	Room 474	RHT
1	2	Room 469	RHT
1	2	Kitchen 468	RHT
1	2	Kitchen	M
1	2	Kitchen	EOL
1	2	North Exit	M
B	1	Bottom of Stairs	S
1		Bottom of Stairs	B
B	1	Kitchen Room 488	RHT
B	1	Kitchen Room 488	EOL

B	1	Laundry Room 487	HT
B	1	Storage 486	RHT
B	1	Boiler Room	HT
B	1	Boiler Room Storage	RHT
B	1	Room 490	RHT
B	1	Room 491	RHT
B	1	Room 491 Exit	M
1		1st Floor Hallway	B
3	4	3rd Floor Hallway	S

CSC Museum (RHQ)

CSC Museum 555 Union Street			
Zone	Address	Location	Device
		Boiler Room	FACP
		12v20ah	Batts
B	5-4	Vault	RHT
B	5-1	Boiler Room 010	RHT
B	5-12	Bottom Of Stairs	M
B		Bottom Of Stairs	H
B	5-2	Outside Storage South	RHT
B	5-3	Storage South	RHT
B	5-8	Workshop Storage 018	RHT
B	5-8	Workshop 019	RHT
B	5-11	Outside Workshop	M
B	5-5	Outside Workshop	S
B	5-6	At Electrical Panels 016	RHT
B	5-7	North West Storage 017	RHT
B	5-10	North West Storage 017	M
1	5-13	Top of BSMT Stairs	S
1	5-28	North Exit	M
1	5-19	North East Showroom 105	S
1	5-18	South East Showroom 104	S
1	5-16	South West Showroom 102	S
1	5-27	South Exit Front	M
1		South Exit	H
1	5-17	North West Showroom 103	S
1	5-15	South Lobby 101	S
1	5-29	Exit From Cells 107	M
1	5-20	Exit From Cells 107	S
1		Outside Washroom	H
1	5-22	Outside Washroom 109	S
1	5-26	Top of Stair (Closet) 109	S
1	5-24	Outside Cells 111	S
1	5-30	Outside Women's Washroom	M
1	5-23	Room 110	RHT
1	5-25	Storage Room Off 109	RHT
1	2-21	Room 108	RHT
2	5-46	Top Of Stairs North at 205	M

2	5-41	Top Of Stairs North at 205	S
2		Top of Stairs North	H
2	5-39	Kitchen 204	RHT
2	5-42	Outside Kitchen 205	S
2	5-44	Office North West 208	RHT
2	5-32	Top Of South Stair 200	S
2		Top Of South Stair 200	H
2	5-45	Top Of South Stair 200	M
2	5-34	North East Showroom 201	S
2	5-35	South East Showroom 201	S
2	5-33	Halfway South 200A	S
2	5-36	South West Showroom 202	S
2	5-43	North West Showroom 206	S
2	5-37	South Office 203	RHT
3	5-54	Top Of Stairs North	S
3	5-52	North West Storage 308	RHT
3	5-50	South West Storage 304	RHT
3		Center Storage	H
3	5-48	Center Storage 301	S
3	5-49	East Storage 302	RHT
2	5-38	Staff Washroom 203B	RHT
3	5-51	West Storage 305	RHT
3	5-53	At Exit 301	M
2	5-40	Kitchen Storage 204	RHT

Stone Gables House and St. Helen's House (RHQ)

Stone Gables 440 Union Street				St. Helen's 440 Union Street			
Zone	Address	Location	Device	Zone	Address	Location	Device
		Main Entrance	FACP			Side Entrance	FACP
		12v7ah x 2	Batts			12v7ah x 2	Batts
						Breaker	
3	4	Room 309	S	1	6	At FACP	M
3	6	Top of Stairs	S	1	6	Top Of Stairs	S
3		Top of Stairs	B	1	6	Room 106	HT
3	4	Top of Stairs	M	1	6	Main Entrance	M
3	4	Top of Stairs	EOL	1	6	Main Entrance	SOL
3		East Hallway	B	1		Bottom Of Stairs	B
3		East Hallway	EOL	2	1	Top Of Stairs	S
3	4	East Exit 302	M	2	1	Top Of Stairs	M
3	4	East Exit	EOL	2	1	Top Of Stairs	EOL
3	4	Room 302	HT	2		Hallway	B
2	6	Top of Stairs	S	B		BSMT Hallway	B
2	3	Outside Room 216	M	3	3	East Exit	M
2		Outside Room 216	B	B	3	Sprinkler Room Storage	HT
2	3	Room 216 Closet	HT	B	3	Room 008	HT
2	3	Room 219 Closet	HT	B	3	South West Exit	M
2	3	Room 217 Closet	HT	B	3	Telephone Room	HT
2		East Exit	B	B	3	Boiler Room 006	HT
2	3	East Exit 202	M	1	9	Gate Valve	TS
2	3	East Room	EOL	1	5	Sprinkler Flow (Dry)	FS
1	2	At FACP	M	1	4	Red Cross	REL
1		At FACP	B	1	8	Morton	REL
1	2	Washroom	HT	1	7	Stone Gables	REL
1	2	North West Exit	M	B	3	Room 009	HT
1		West Area	B	B	3	Room 005A	HT
1	2	West Area	EOL				
1	2	Room 103	RHT				
1		Outside Room 208	B				
1	2	Room 101	HT				
1	2	East Top of BSMT Stairs	M				
1	2	East Top of BSMT Stairs	S				
B	1	Bottom Of East Stairs	M				
B		South East BSMT	B				
B	1	South East BSMT 001	RHT				
B	1	South East BSMT Storage	HT				
B	1	Electical Room 005	HT				
B	1	Electical Room	EOL				
B	1	Water Heater Room 011	HT				
B	1	Boiler Room 011	HT				
B	1	Room 014	HT				
B	1	West Room 013	HT				
B	1	West Washroom 012	HT				
B	1	Bottom of stair West	M				

Red Cross House and Morton House (RHQ)

Red Cross House 440 Union Street				Morton House 440 Union Street			
Zone	Address	Location	Device	Zone	Address	Location	Device
		Main Entrance	FACP			Main Entrance	FACP
		12v7ah x 2	Batts			12v7ah x 2	Batts
1	1	Main Entrance	M	1	1	Main Entrance	M
1		Main Entrance	B	1		Main Entrance	B
1	1	Outside Room 102	HT	1	1	Kitchen 1	HT
1		Outside Room 101	B	1		Outside Rm 109	B
1	1	North West Exit	M	1	SIG	Outside Rm 109	EOL
1	1	Outside Room 115	M	1	1	Outside Rm 109	M
1		Room 113	B	1	1	Outside Rm 109	EOL
1	1	Room 122 Exit	M	1	1	Top of North East Stair	S
1	1	Room 122 Exit	EOL	1	4	Closet at top of NE Stair	DS
1	1	Room 113	EOL	B	2	East exit	M
B	2	Outside Room 007	M	B	2	Room 000 Vault	RHT
B		Outside Room 006	B	B		Exit to North East Stair	B
B		Outside Room 011	B	B	2	Exit to North East Stair	M
B		Outside Room 004	B	B	2	Exit to North East Stair	EOL
B	2	Outside Room 001	M	B	2	Room 007	RHT
B	2	Outside Room 001	EOL	B	2	Room 007A	HT
B	4	Telephone Room	S	B	2	Exit at Room 013	M
B	3	Furnace Room	DS	B	2	Room 013	RHT
B		Furnace Room	B	B	2	Room 013 Cage	RHT
B	2	Furnace Room 012	HT	1	1	Top of South West Stair	S
B	2	Furnace Room 011	HT	B	2	Bottom of SW Stairs	M
B	2	Room 009	HT	B		Outside Washrooms	B
B	2	Room 009	HT	B	2	Office Area 019	RHT
B	2	Electrical Room	HT	B	2	Boiler Exit	M
				B	2	Boiler Room	B
				B	2	Boiler Room	HT
				B	2	Boiler Room	HT
				B	2	Boiler Room Storage	RHT
				B	2	Boiler Room	DS
				B	2	Garage	HT
				B	2	Northwest Garage Storage	HT
				B	2	Northwest Garage Storage	EOL
				B	2	Southwest Garage Storage	HT

Main Building 508 Portsmouth (RHQ)

Main 508 Portsmouth Ave			
Zone	Address	Location	Device
		Main Entrance	FACP
	2021	12v26ah	Batts
2	1-32	Outside 209	S
2	1-22	Outside 209	M
2		Outside 209	B
2	1-34	Top Of Stairs 3	S
2	1-36	Room 203	S
2	1-35	Room 206	S
2	1-31	Room 207	S
2	1-30	Room 209	S
2	1-25	Top Of Stairs 2	S
2	1-21	Outside 215	M
2		Outside 215	B
2	1-23	Outside 215	S
2	1-24	Outside 215	S
2	1-26	Room 212	S
2	1-27	Room 214	S
2	1-29	Room 215	S
2	1-28	Room 215	S
1	1-01	West Exit	M
1		West Exit	B
1	1-07	Room 115	S
1	1-09	Room 117	S
1	1-06	Room 114	S
1	1-08	At FACP	S
1	1-10	Bottom of Stairs 2	S
1	1-11	Room 118	RHT
1	1-02	Outside 112	M
1	1-04	Outside 112	S
1	1-05	Room 112	S
1	1-12	Room 108	S
1	1-15	Room 106	S
1	1-16	Room 105	S
1		Outside Room 106	B
1	1-03	Outside Room 106	M

1	1-13	Room 107	S
B	1-42	Bottom Of Stairs	M
B	1-45	Bottom of Stairs	S
B	1-46	Workshop	S
B	1-50	Workshop	RHT
B		At Electrical Panel	B
B	1-47	At Electrical Panel	S
B	1-48	At Telephone Blocks	RHT
B	1-49	Adjacent Telephone Blocks	RHT
B		Outside Electrical Storage	B
B	1-44	Electrical Storage	RHT
B	1-53	At Monitoring	S
B	1-43	Laundry Room	RHT
B	1-41	Boiler Room	M
B	1-52	Boiler Room	RHT
B	1-51	Boiler Room	RHT
1	1-14	Outside Room 106	S

Annex Building 508 Portsmouth (RHQ)

Annex 508 Portsmouth Ave			
Zone	Address	Location	Device
B	2-01	BSMT at Stairs	M
B	2-02	BSMT West Exit	M
B	2-03	BSMT Beside Sprinkler	S
B	2-04	BSMT Furnace	S
B	2-05	BSMT at Networking	S
B	2-06	Attic Sprinkler	FS
B	2-07	Main Flow	FS
B	2-08	Attic Low Air	PS
B	2-09	Sprinkler Low Pressure	PS
B	2-12	1st Floor Flow	FS
B	2-13	BSMT Flow	FS
1	2-16	West Exit	M
1	2-17	East Exit	M
1	2-18	East Exit	RHT
1	2-19	Stair 1	S
1	2-21	Outside Room 123	S
1	2-22	Outside Room 114	S
1	2-23	Outside Room 126	S
1	2-24	Room 104	S
1	2-25	Room 107	S
1	2-26	Room 112	S
1	2-27	Room 109	S
1	2-28	Room 113	S
1	2-29	Room 114	S
1	2-30	Room 115	S
1	2-31	Room 118	S
1	2-32	Room 119	S

1	2-33	Room 124	S
1	2-34	Room 102A	S
1		East Exit	B
1		Outside Room 119	B
1		Outside Room 114	B
1		Outside Room 112	B
1	2-20	West Exit	RHT
B		Outside Room 05	B
B	2-11	Main Dry Supervisory Valve	TS
B	2-11	Main Wet Supervisory Valve	TS
B	2-10	BSMT Supervisory Valve	TS
B	2-10	BSMT Supervisory Valve	TS
B		At Networking Cage	B

Sprinkler Systems:

Sprinkler Device/Valve/Zones Record

Site	Zones /Valves/Devices	Location	Size	Type
508 Portsmouth Avenue	508 Portsmouth Ave. Wet System			
	508 Portsmouth Ave. Dry System			
	508 Portsmouth Ave. Basement Flow	Basement	2"	Potter
	4" BFV Attic Dry Valve	Basement	4"	Waffer
	4" BFV Attic Dry Low Air pressure	Basement		PS40
	4" BFV Attic Dry Flow	Basement		PS10
	Wet Valve	Basement	4"	Waffer
	Wet Ground Floor Valve	Basement	2.5"	Waffer Flow
	Wet Valve Basement	Basement	2"	OS&Y Flow
	Wet Main Flow	Basement		PS10
	Wet Low Pressure	Basement		PS120
	Ground Floor Flow	Basement	2.5"	Potter
443 Union Street National Training Academy	443 Union Street Wet System			
	443 Union Street Backflow			
	Backflow Inlet	Basement	3"	BFV
	Backflow Outlet	Basement	3"	BFV
	2x Standpipe	Basement	2.5"	BFV
	Sprinkler Valve	Basement	1.25"	BBV
446 Union Street Westlake Hall	446 Union Street Wet System			
	446 Union Street Backflow			
	Backflow Inlet & Outlet Valve	Basement	3"x2	BFV
	1st and 2nd Floor Valves	Basement	2.5"x2	BFV
	1st and 2nd Floor flows	Basement	2.5"x2	Potter

Sprinkler Systems: cont

Sprinkler Device/Valve/Zones Record				
445 Union Street RHQ	445 Union Street Wet System			
	445 Union Street Pre-Action Backflow			
	BFP 2	1st Floor Sprinkler Room	6"	BFV
	Main 1	1st Floor Sprinkler Room	6"	OS&Y
	Sprinkler 1	1st Floor Sprinkler Room	6"	BFV
	Window Sprinkler	1st Floor Sprinkler Room	4"	BFV
	Flow	1st Floor Sprinkler Room	4"	Potter
	Sprinkler Pressure	1st Floor Sprinkler Room		PS120
	Sprinkler Flow	1st Floor Sprinkler Room		PS10
	2-Preaction	1st Floor Sprinkler Room	2"	BFV
	2-Preaction	1st Floor Sprinkler Room		PS10
	2-Preaction	1st Floor Sprinkler Room		PS40
	Sprinkler Valve	1st Floor Sprinkler Room	4"	BFV
	Sprinkler Flow	1st Floor Sprinkler Room	4"	Potter
	Sprinkler Valve	2nd Fl Janitor	4"	BFV
	Sprinkler Flow	2nd Fl Janitor	4"	Potter
	Sprinkler Valve	3rd Fl Janitor	4"	BFV
Sprinkler Flow	3rd Fl Janitor	4"	Potter	