

Addendum / Addenda

Project Description / Description de projet		
CHORD Antenna Production Facility Heating, Ventilation & Air Conditioning System Construction		
Solicitation No./N° de sollicitation	Project No./N° de projet	W.O. No./N° d'ordre de travail
26-58067		
Departmental Representative / représentant ministériel		Date
Brian Hoff		2023-08-22
<p>Notice:</p> <p>This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.</p>		<p>Nota:</p> <p>Cet addenda fait partie intégrale des dossiers d'appel; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.</p>

1 Bidder question and response

Bidder question:

I'm reaching out this morning to see if we can consider making the electrical portion of this project a cash allowance. I'm getting a lot of electrical contractors not wanting to bid this project as it is a design build for them with no drawings or specifications, as of right now I have one out of ten companies I sent this to bidding this project.

NRC response:

Since the electrical portion of this tender consists only of connecting the power supply cables, which will be installed by NRC complete with disconnect switches, to RTU-1 and RTU-2, as well as connecting thermostat cables to these units, it must be included in the offer and cannot be made a cash allowance.